

CITY OF
WEST CHICAGO

Approved 11/23/10

**WEST CHICAGO HISTORICAL PRESERVATION COMMISSION
SPECIAL MEETING NOVEMBER 4, 2010**

Members Present:

Tony Chinn
Janet Hale
Garth Keck
Sharon Plante

Guests:

LuAnn Bombard

Members Absent:

Stephen Schneider
Jennifer Timbrook
Richard Visgnes

1. Call to Order, Roll Call and Establishment of a Quorum

Meeting called to order at 7:06 p.m. Quorum established.

2. COA Review – 119 W. Washington – Roof and gutters

Ms. LuAnn Bombard, City Museum Director, presented information on behalf of the City. Application of the gutters must be made with straps because the fascia is tipped and does not allow for brackets. Straps will be attached to the mortar joints. The gutters will be six inch half round, single bead. The downspouts will be four inch round single bead. There will be three downspouts each on the east and west sides. The gutters, downspouts and straps will be “Navaho” in color to match the brick. The roof will be shingled with an architectural shingle in a similar quality and color to the “Brownwood” sample that was presented. Motion to approve as presented was made by Commissioner Keck and seconded by Commissioner Plante. Motion carried with an all aye vote.

3. Adjournment

Motion to adjourn was made by Commissioner Hale and seconded by Commissioner Keck. Meeting adjourned at 7:30 p.m.