



GENERAL NOTES:

- MANHOLE LIDS SHALL BE NEENAH R1772 TYPE "B" SELF SEALING LID OR EJIW 1022-1 HD OR APPROVED EQUAL.
- EZ-STICK GASKET OR APPROVED EQUAL SHALL BE INSTALLED AT ALL JOINTS.
- EXTERNAL CHIMNEY SEALS TO BE CANUSA, INFISHIELD OR APPROVED EQUAL.
- EXTERNAL JOINT SEALS TO BE MAC-WRAP OR APPROVED EQUAL.
- CONCRETE ADJUSTING RINGS NOT TO EXCEED 12" IN HEIGHT AND 3 IN NUMBER.
- PIPE ENDS SHALL BE CUT FLUSH WITH MANHOLE WALLS. NO PROTRUDING PIPE IS ALLOWED.

STANDARD SAN-001



CITY OF WEST CHICAGO
 475 MAIN STREET
 WEST CHICAGO, IL 60185
 PHONE: 630-293-2255
 FAX: 630-293-2971

SANITARY SEWER MANHOLE

CITY OF WEST CHICAGO
 CONSTRUCTION SPECIFICATIONS,
 STANDARDS, AND DETAILS

REVISIONS

NO.	DESCRIPTION