



GENERAL NOTES:

STRUCTURE'S BOTTOM SECTION SHALL BE USED FOR THRUST BLOCKING

BACKFILL SHALL BE MECHANICALLY COMPACTED AND SHALL BE PLACED AT THE FOLLOWING GRADES:

- EARTH - 6" BELOW EXISTING GROUND ELEVATION
- PAVED AREA - 1' BELOW PAVEMENT SUB-BASE

STANDARD WM-003



CITY OF WEST CHICAGO
 475 MAIN STREET
 WEST CHICAGO, IL 60185
 PHONE: 630-293-2255
 FAX: 630-293-2971

VALVE VAULT ABANDONMENT

CITY OF WEST CHICAGO
 CONSTRUCTION SPECIFICATIONS,
 STANDARDS, AND DETAILS

REVISIONS

NO.	DESCRIPTION