



**GENERAL NOTES:**

PAINT COATINGS SHALL BE SHERWIN WILLIAMS BRAND, INDUSTRIAL URETHANE ALKYD ENAMEL, SERIES B54-150

COLOR REQUIREMENTS SHALL BE FOLLOWING:  
 PUBLIC (POTABLE) - SAFETY YELLOW  
 PUBLIC (RAW) - SAFETY GREEN  
 PRIVATE (POTABLE) - SAFETY RED

HYDRANTS SHALL BE SUPPLIED WITH ATTACHED AUXILIARY VALVES

ALL MJ FITTINGS SHALL REQUIRE MEGALUGS

WHEN ELEVATIONS PREVENT MINIMUM COVER OVER THE HYDRANT LEAD (E.G. DITCH), VERTICAL BENDS SHALL BE PROVIDED BETWEEN THE TEE AND AUXILIARY VALVE BY ROLLING THE HYDRANT TEE DOWNWARD

FIRE HYDRANTS SHALL BE CONSTRUCTED AND CLEARED FROM ABOVE GROUND OBJECTS AT A MINIMUM DISTANCE OF 48"

ALL HYDRANTS INSTALLED ON 12" OR LARGER SHALL BE INSTALLED ON LOCKING HYDRANT TEES WHERE AVAILABLE

ALL HYDRANT LEADS SHORTER THAN 48" SHALL BE SECURED WITH STAINLESS STEEL ROD CONNECTED TO THE MAIN

COVER WITH POLY PLASTIC SHEET

CONC. THRUST BLOCK (TYP)

DO NOT OBSTRUCT HYDRANT DRAIN

1 CY MIN. CA-7

UNDISTURBED EARTH

STANDARD WM-006



CITY OF WEST CHICAGO  
 475 MAIN STREET  
 WEST CHICAGO, IL 60185  
 PHONE: 630-293-2255  
 FAX: 630-293-2971

**FIRE HYDRANT**

CITY OF WEST CHICAGO  
 CONSTRUCTION SPECIFICATIONS,  
 STANDARDS, AND DETAILS

REVISIONS

NO.	DESCRIPTION