



- 1 - BACKFLOW PREVENTOR
- 2 - BALL VALVE

GENERAL NOTES:

REFER TO NEPTUNE METER INSTALLATION INSTRUCTION FOR ADDITIONAL GENERAL AND INSTALLATION REQUIREMENTS.

ALL WATER METER BE INSTALLED HORIZONTALLY. VERTICAL INSTALLMENT SHALL BE PROHIBITED.

BONDING OF ELECTRICAL SYSTEM TO THE WATER METER SHALL NOT BE ALLOWED.

SPRINKLER METERS ARE TO BE INSTALLED AFTER MAIN METER TO RECEIVE METERING CREDIT.

COMBINED WATER SERVICE 2" AND SMALLER DOMESTIC SUPPLY 1-1/2"

STANDARD WM-009



CITY OF WEST CHICAGO
 475 MAIN STREET
 WEST CHICAGO, IL 60185
 PHONE: 630-293-2255
 FAX: 630-293-2971

COMMERCIAL METER DETAIL-A

CITY OF WEST CHICAGO
 CONSTRUCTION SPECIFICATIONS,
 STANDARDS, AND DETAILS

REVISIONS	