



**GENERAL NOTES:**

ALL FASTENER HARDWARE (I.E. NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE WATERMAIN AND CASING SPACERS SHALL BE STAINLESS STEEL.

<u>WATERMAIN DIA.</u>	<u>CASING PIPE DIA.</u>
6"	12"
8"	15"
10"	18"
12"	18"

CONFLICTS OCCUR WHERE WATERMANS PASS WITHIN 18" OVER OR PASS UNDER A SANITARY AND/OR STORM SEWER AND SHALL BE PROVIDED FOR AS FOLLOWS:

**SANITARY CONFLICTS:**

PROVIDE WATERMAIN EQUIVALENT PIPE AND JOINTS FOR THE SANITARY SEWER 10 FT. EITHER SIDE OF WATERMAIN CROSSING USING MISSION TYPE COUPLINGS TO MAKE THE TRANSITION BETWEEN THE TWO MATERIALS, OR ENCASE WATERMAIN AS SHOWN BELOW, REGARDLESS OF METHOD, THERE SHALL BE A MINIMUM 18" CLEARANCE BETWEEN TOP OF WATERMAIN AND THE BOTTOM OF THE SANITARY SEWER.

**STORM SEWER CONFLICTS:**

PROVIDE STORM SEWER PIPE WITH O-RING GASKET JOINTS CONFORMING TO ASTM C-361 10 FT. EITHER SIDE OF WATERMAIN CONFLICTS AND PROVIDE A MINIMUM CLEARANCE BETWEEN TOP OF WATERMAIN AND THE BOTTOM OF THE STORM SEWER.

STANDARD WM-012



CITY OF WEST CHICAGO  
 475 MAIN STREET  
 WEST CHICAGO, IL 60185  
 PHONE: 630-293-2255  
 FAX: 630-293-2971

**WATERMAIN CONFLICT**

CITY OF WEST CHICAGO  
 CONSTRUCTION SPECIFICATIONS,  
 STANDARDS, AND DETAILS

REVISIONS

NO.	DESCRIPTION