



**GENERAL NOTES:**

THE CASING SPACER SHALL BE THE CENTERED AND RESTRAINED TYPE.

THE SPACER BANDS SHALL BE STAINLESS STEEL.

ALL FASTENER HARDWARE (I.E. NUTS, BOLTS, AND WASHERS) ASSOCIATED WITH THE CASING SPACERS SHALL BE STAINLESS STEEL.

THE SPACERS SHALL BE STAINLESS STEEL OR APPROVED EQUAL.

STANDARD WM-013



CITY OF WEST CHICAGO  
 475 MAIN STREET  
 WEST CHICAGO, IL 60185  
 PHONE: 630-293-2255  
 FAX: 630-293-2971

**UNDERGROUND UTILITY CASING PIPE**

CITY OF WEST CHICAGO  
 CONSTRUCTION SPECIFICATIONS,  
 STANDARDS, AND DETAILS

REVISIONS
